

WAYNE VALLEY HIGH SCHOOL
551 VALLEY ROAD

KEY: TNR: TESTING NOT REQUIRED			
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION			
ND: None Detected BS: Below DEP / EPA Standard			
* Retest Date 4/27/17 & 5/26/17	SP: NON POTABLEWATER (NOT FOR DRINKING) HAND WASHING ONLY	Test Dates: 11/10/2016 & 6/11/2017	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	MEDIAL ACTION NOTI
L6439888-1	LAB 222 ISLAND 1 SIDE SINK	>15 ppb	TNR/ SP
L6439888-2	CLASSROOM 215 SINK 6	>15 ppb	TNR/ SP
L6439888-3	LAB 222 ISLAND 5 SINK	>15 ppb	TNR/ SP
L6439888-4	LAB 222 ISLAND 5 SIDE SINK	>15 ppb	TNR/ SP
L6439888-5	CLASSROOM 225 SIDE SINK	>15 ppb	TNR/ SP
L6439888-6	CLASSROOM 225 FRONT SINK	<15 ppb	TNR/BS
L6439888-7	CLASSROOM 223 ISLAND 4 SINK	<15 ppb	TNR/BS
L6439888-8	FIELD HOUSE SINK	>15 ppb	REMOVED
L6439888-9	CLASSROOM 224 ISLAND 4 SINK	>15 ppb	TNR/ SP
L6439888-10	LAB 222 ISLAND 2 SINK	>15 ppb	TNR/ SP
L6439888-11	LAB 222 ISLAND 1 SINK	>15 ppb	TNR/ SP
L6439888-12	LAB 222 ISLAND 3 BACK SINK	>15 ppb	TNR/ SP
L6439888-13	LAB 222 ISLAND 4 SINK	>15 ppb	TNR/ SP
L6439888-14	LAB 222 ISLAND 3 SINK	>15 ppb	TNR/ SP
L6439888-15	CLASSROOM 213 SINK 1	* >15 ppb	TNR/ SP
L6439888-16	BACK KITCHEN SINK RIGHT	* >15 ppb	TNR/ SP
L6439888-17	CLASSROOM 222 PREP ROOM SINK	<15 ppb	TNR/BS
L6439888-18	CLASSROOM 224 ISLAND 2 SINK	>15 ppb	TNR/ SP
L6439888-19	CLASSROOM 223 FRONT SINK	< 15 ppb	TNR/BS
L6439888-20	CLASSROOM 223 ISLAND 2 SINK	>15 ppb	TNR/ SP
L6439888-21	CLASSROOM 224 ISLAND 6 SINK	>15 ppb	TNR/ SP
L6439888-22	CLASSROOM 224 ISLAND 3 SINK	14.000	TNR/BS
L6439888-23	NURSES OFFICE BATHROOM SINK	2.070	BS
L6439888-24	CLASSROOM 215 BACK OFFICE SINK	>15 ppb	TNR / SP
L6439888-25	CLASSROOM 224 ISLAND 1 SINK	>15 ppb	TNR/ SP
L6439888-26	CLASSROOM 213 ISLAND SINK 3	>15 ppb	TNR/ SP
L6439888-27	CLASSROOM 223 ISLAND 6 SINK	<15 ppb	TNR/BS
L6439888-28	CLASSROOM 215 SINK 3	>15 ppb	TNR/ SP
L6439888-29	LAB 222 FRONT SINK	<15 ppb	TNR/BS
L6439888-30	CLASSROOM 213 SINK 6	>15 ppb	TNR/ SP
L6439888-31	CLASSROOM 212 SINK	<15 ppb	TNR/BS
L6439888-32	BACK KITCHEN SINK LEFT	10.900	BS

**WAYNE VALLEY HIGH SCHOOL
551 VALLEY ROAD**

KEY: TNR: TESTING NOT REQUIRED			
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION			
ND: None Detected BS: Below DEP / EPA Standard			
* Retest Date 4/27/17 & 5/26/2017	SP: NON POTABLEWATER (NOT FOR DRINKING) HAND WASHING ONLY	Test Dates: 11/10/2016 & 6/11/2017	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439888-33	FOUNTAIN RIGHT BY ROOM 222	1.690	BS
L6776663-6	OUTSIDE SPIGOT BY BACK KITCHEN	* ND	BS
L6439888-35	FOUNTAIN LEFT BY ROOM 222	12.500	BS
L6439888-36	CLASSROOM 215 SINK 2	>15 ppb	TNR/ SP
L6439888-37	LAB 222 ISLAND 6 SINK	>15 ppb	TNR/ SP
L6439888-38	CLASSROOM 225 BACK SINK	>15 ppb	TNR/ SP
L6439888-39	OUTSIDE FOUNTAIN BY FENCE	2.880	BS
L6439888-40	CLASSROOM 215 FRONT SINK	<15 ppb	TNR/BS
L6439888-41	CLASSROOM 224 FRONT SINK	<15 ppb	TNR/BS
L6439888-42	CLASSROOM 223 ISLAND 1 SINK	<15 ppb	TNR/BS
L6439888-43	CLASSROOM 223 ISLAND 3 SINK	<15 ppb	TNR/BS
L6439888-44	CLASSROOM 223 ISLAND 5 SINK	>15 ppb	TNR/ SP
L6439888-45	CLASSROOM 215 SINK 4	>15 ppb	TNR/ SP
L6439888-46	CLASSROOM 213 SINK 4	>15 ppb	TNR/ SP
L6439888-47	CLASSROOM 213 SINK 2	>15 ppb	TNR/ SP
L6439888-48	CLASSROOM 224 ISLAND 5 SINK	<15 ppb	TNR/BS
L6439888-49	CLASSROOM 213 FRONT SINK	>15 ppb	TNR/ SP
L6439888-50	NURSES OFFICE SINK	2.050	BS
L6439888-51	CLASSROOM 213 SINK 5	>15 ppb	TNR/ SP
L6439888-52	CLASSROOM 215 SINK 5	<15 ppb	TNR/BS
L6439888-53	LAB 254 ISLAND 3 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-54	CLASSROOM 203 SINK	>15 ppb	TNR/ SP
L6439888-55	LAB 253 ISLAND 6 SINK LEFT	>15 ppb	TNR/ SP
L6439888-56	LAB 254 ISLAND 1 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-57	CLASSROOM 211 FRONT SINK	>15 ppb	TNR/ SP
L6439888-58	LAB 251 ISLAND 4 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-59	LAB 256 ISLAND 2 SINK LEFT	>15 ppb	TNR/ SP
L6439888-60	LAB 256 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439888-61	FOUNTAIN LEFT BY LAB 253	1.380	BS
L6439888-62	LAB 254 SIDE SINK	<15 ppb	TNR/BS
L6439888-63	LAB 253 ISLAND 3 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-64	LAB 251 ISLAND 2 SINK LEFT	>15 ppb	TNR/ SP
L6439888-65	ART ROOM 118 SINK 3	>15 ppb	TNR/ SP
L6439888-66	LAB 254 FRONT SINK	>15 ppb	TNR/ SP

WAYNE VALLEY HIGH SCHOOL

551 VALLEY ROAD

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

*** Retest Date
4/27/17 &
5/26/2017**

**SP: NON POTABLEWATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/10/2016 & 6/11/2017

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439888-67	LAB 256 ISLAND 3 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-68	ART ROOM 118 SINK 1	>15 ppb	TNR/ SP
L6439888-69	LAB 256 ISLAND 3 SINK LEFT	>15 ppb	TNR/ SP
L6439888-70	LAB 256 ISLAND 6 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-71	LAB 254 ISLAND 5 SINK LEFT	>15 ppb	TNR/ SP
L6439888-72	LAB 251 ISLAND 5 SINK LEFT	>15 ppb	TNR/ SP
L6439888-73	LAB 254 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439888-74	ART ROOM 118 SINK 2	>15 ppb	TNR/ SP
L6439888-75	LAB 254 ISLAND 3 SINK LEFT	>15 ppb	TNR/ SP
L6439888-76	LAB 253 ISLAND 1 SINK LEFT	>15 ppb	TNR/ SP
L6439888-77	LAB 253 OFFICE SINK	>15 ppb	TNR/ SP
L6439888-78	LAB 254 ISLAND 6 SINK LEFT	>15 ppb	TNR/ SP
L6439888-79	LAB 254 PREP ROOM SINK	<15 ppb	TNR/BS
L6439888-80	LAB 253 ISLAND 5 SINK LEFT	>15 ppb	TNR/ SP
L6439888-81	LAB 254 ISLAND 6 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-82	LAB 254 ISLAND 2 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-83	CLASSRRROM 211 OFFICE SINK	7.910	BS
L6439888-84	ART ROOM 219 SINK 1	>15 ppb	TNR/ SP
L6439888-85	LAB 256 ISLAND 5 SINK LEFT	>15 ppb	TNR/ SP
L6439888-86	LAB 254 ISLAND 1 SINK LEFT	>15 ppb	TNR/ SP
L6439888-87	LAB 254 ISLAND 4 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-88	LAB 253 ISLAND 5 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-89	LAB 254 ISLAND 2 SINK LEFT	<15 ppb	TNR/BS
L6439888-90	LAB 253 ISLAND 6 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-91	LAB 251 ISLAND 1 SINK LEFT	>15 ppb	TNR/ SP
L6439888-92	LAB 256 ISLAND 1 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-93	ART ROOM 219 SINK 2	>15 ppb	TNR/ SP
L6439888-94	LAB 256 ISLAND 5 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-95	LAB 256 ISLAND 1 SINK LEFT	>15 ppb	TNR/ SP
L6439888-96	LAB 254 ISLAND 5 SINK RIGHT	<15 ppb	TNR/BS
L6439888-97	LAB 251 ISLAND 1 SINK RIGHT	<15 ppb	TNR/BS
L6439888-98	LAB 251 ISLAND 5 SINK RIGHT	>15 ppb	TNR/ SP
L68235851-1	FOUNTAIN BY 203	* ND	SP
L6439888-100	LAB 253 ISLAND 2 SINK RIGHT	>15 ppb	TNR/ SP

WAYNE VALLEY HIGH SCHOOL
551 VALLEY ROAD

KEY: TNR: TESTING NOT REQUIRED			
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION			
ND: None Detected BS: Below DEP / EPA Standard			
* Retest Date 4/27/17 & 5/26/17	SP: NON POTABLEWATER (NOT FOR DRINKING) HAND WASHING ONLY	Test Dates: 11/10/2016 & 6/11/2017	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439888-101	LAB 253 ISLAND 4 SINK RIGHT	<15 ppb	TNR/BS
L6776663-8	FOUNTAIN RIGHT BY LAB 253	* ND	REPLACED- BS
L6439888-103	LAB 253 ISLAND 3 SINK LEFT	>15 ppb	TNR/ SP
L6439888-104	LAB 251 ISLAND 6 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-105	LAB 251 ISLAND 2 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-106	LAB 251 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439888-107	LAB 251 SIDE SINK	>15 ppb	TNR/ SP
L6439888-108	LAB 251 FRONT SINK	>15 ppb	TNR/ SP
L6439888-109	CLASSROOM 203 OFFICE SINK	>15 ppb	TNR / SP
L6439888-110	ART ROOM 219 SINK 3	>15 ppb	TNR / SP
L6439888-111	FOUNTAIN BY ROOM 247	11.900	BS
L6439888-112	LAB 253 ISLAND 1 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-113	LAB 253 ISLAND 4 SINK LEFT	>15 ppb	TNR/ SP
L6439888-114	FOUNTAIN LEFT BY 220	<.00050	BS
L6439888-115	LAB 256 ISLAND 6 SINK LEFT	>15 ppb	TNR/ SP
L6439888-116	LAB 251 ISLAND 6 SINK LEFT	>15 ppb	TNR/ SP
L6439888-117	LAB 256 ISLAND 2 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-118	LAB 256 ISLAND 4 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-119	LAB 251 ISLAND 3 SINK RIGHT	>15 ppb	TNR/ SP
L6439888-120	LAB 253 ISLAND 2 SINK LEFT	>15 ppb	TNR/ SP
L6439888-121	FOUNTAIN RIGHT BY 220	1.260	BS
L6439888-122	LAB 253 SINK FRONT	>15 ppb	TNR/ SP
L6439888-123	LAB 256 FRONT SINK	<15 ppb	TNR/BS
L6439888-124	LAB 251 ISLAND 3 SINK LEFT	>15 ppb	TNR/ SP
L6439888-125	CLASSROOM 102 SINK	<15 ppb	TNR/BS
L6439888-126	CLASSROOM 100 FOUNTAIN	<.00050	BS
L6439888-127	CLASSROOM 116 SINK 4	<15 ppb	TNR/BS
L6439888-128	FOUNTAIN RIGHT BY BOYS 157	6.000	BS
L6439888-129	FOUNTAIN BY OFFICE 155	<.00050	BS
L6439888-130	LADIES ROOM SINK IN MAIN OFFICE	<.00050	TNR/BS
L6439888-131	CLASSROOM 114 SINK 6	<15 ppb	TNR/BS
L6776663-2	ICE MAKER IN TRAINING ROOM	* ND	BS
L6439888-133	FOUNTAIN IN WEIGHT ROOM 128	1.180	BS
L6439888-134	FOUNTAIN LEFT BY 141	<.00050	BS

WAYNE VALLEY HIGH SCHOOL

551 VALLEY ROAD

KEY: TNR: TESTING NOT REQUIRED

DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION

ND: None Detected BS: Below DEP / EPA Standard

*** Retest Date
4/27/17 &
5/26/17**

**SP: NON POTABLE WATER (NOT FOR DRINKING)
HAND WASHING ONLY**

Test Dates: 11/10/2016 & 6/11/2017

SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439888-135	BOYS LOCKER ROOM OFFICE SINK	3.500	BS
L6439888-136	KITCHEN SIDE SINK 1	1.220	BS
L6439888-137	CLASSROOM 104 SINK	<15 ppb	TNR/BS
L6439888-138	FOUNTAIN BY ROOM 145	4.770	BS
L6439888-139	CLASSROOM 114 SINK 3	<15 ppb	TNR/BS
L6439888-140	CLASSROOM 100 SINK	<.00050	TNR/BS
L6439888-141	BOYS LOCKER ROOM 127 OFFICE SINK	1.210	BS
L6776663-3	SMALL GYM FOUNTAIN	* 1.600	REPLACED- BS
L6439888-143	GIRLS LOCKER ROOM 125 OFFICE SINK	<.00050	BS
L6439888-144	BOYS LOCKER 127 FOUNTAIN	1.030	BS
L6439888-145	FOUNTAIN RIGHT BY 141	<.00050	BS
L6439888-146	KITCHEN LARGE SINK REAR RIGHT ON ISLAND	3.490	BS
L6439888-147	OFFICE 103 SINK	0.870	BS
L6439888-148	CLASSROOM 116 SINK 3	<.00050	TNR/BS
L6439888-149	FOUNTAIN IN TRAINING ROOM	1.560	BS
L6776663-7	CLASSROOM 130 FOUNTAIN	* >15 PPB	REMOVED
L6439888-151	KITCHEN ICE MAKER	<.00050	BS
Sampl 6/11/17	Bubblers at Field Fence	Waiting for Result	Waiting for Result
L6439888-153	KITCHEN SMALL SINK REAR	2.880	BS
L6439888-154	CLASSROOM 116 SINK 1	<.00050	TNR/BS
L6439888-155	KITCHEN FACET BY STOVE	<.00050	BS
L6439888-156	KITCHEN LARGE SINK REAR LEFT ON ISLAND	7.860	BS
L6439888-157	CLASSROOM 129 FOUNTAIN	5.810	BS
L6439888-158	FOUNTAIN BY ROOM 152	0.700	BS
L6439888-159	FOUNTAIN LEFT BY GIRLS ROOM 171	1.820	BS
L6439888-160	TRAINING ROOM COACH'S SINK RIGHT	4.520	BS
L6439888-161	CLASSROOM 116 SINK 2	<15 ppb	TNR/BS
L6439888-162	GIRLS LOCKER ROOM 125 FOUNTAIN	13.100	BS
L6439888-163	OFFICE 126 SINK	0.980	BS
L6439888-164	KITCHEN SINK REAR SMALL ON ISLAND	3.760	BS
L6439888-165	KITCHEN SINK 2	0.650	BS
L6439888-166	CLASSROOM 132 SINK	<15 ppb	TNR/BS
L6439888-167	CLASSROOM 106 SINK	<15 ppb	TNR/BS

WAYNE VALLEY HIGH SCHOOL

551 VALLEY ROAD

KEY: TNR: TESTING NOT REQUIRED			
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION			
ND: None Detected BS: Below DEP / EPA Standard			
* Retest Date 4/27/17 & 5/26/17	SP: NON POTABLEWATER (NOT FOR DRINKING) HAND WASHING ONLY	Test Dates: 11/10/2016 & 6/11/2017	
SAMPLE NUMBER	SAMPLE DESCRIPTION / LOCATION	FIRST DRAW TEST RESULTS	REMEDIAL ACTION NOTES
L6439888-168	ENGLISH OFFICE SINK	3.890	BS
L6439888-169	MAIN GYM FOUNTAIN BY GIRLS LOCKER	2.950	BS
L6439888-170	CLASSROOM 116 SINK 5	<15 ppb	TNR/BS
L6439888-171	CLASSROOM 114 SINK 5	<15 ppb	TNR/BS
L6439888-172	PRINCIPAL'S OFFICE SINK	2.490	BS
L6439888-173	GIRLS LOCKER ROOM MAIN OFFICE SINK	>15 ppb	TNR / SP
L6439888-174	FOUNTAIN RIGHT BY CAFETERIA	1.360	BS
L6439888-175	CLASSROOM 114 FRONT SINK 1	<15 ppb	TNR/BS
L6439888-176	KITCHEN SINK FRONT RIGHT	1.620	BS
L6439888-177	FOUNTAIN LEFT BY CAFETERIA	4.040	BS
L6439888-178	OFFICE 126 FOUNTAIN	<.00050	BS
L6439888-179	FOUNTAIN LEFT BY MAIN OFFICE	<.00050	BS
L6439888-180	CLASSROOM 114 SINK 2	<15 ppb	TNR/BS
L6439888-181	FOUNTAIN RIGHT BY GIRLS ROOM 171	1.520	BS
L6439888-182	FACULTY SINK IN MAIN OFFICE	>15 ppb	Disconnected Outlet/ SP
L6439888-183	FOUNTAIN BY 130	0.550	BS
L6776663-9	TRAINING ROOM COACHES SINK LEFT	* ND	BS
L6439888-185	CLASSROOM 102 FOUNTAIN	<.00050	BS
L6439888-186	KITCHEN SIDE SINK 3	1.390	BS
L6439888-187	FOUNTAIN LEFT BY BOYS 158	>15 ppb	Disconnected Outlet
L6439888-188	CLASSROOM 153 SINK	<15 ppb	TNR/BS
L6439888-189	CLASSROOM 114 SINK 4	<15 ppb	TNR/BS
L6439888-190	FOUNTAIN BY CLASSROOM 163	10.700	BS
L6439888-191	KITCHEN SINK ON SMALL ISLAND	<15 ppb	BS
L6439888-192	KITCHEN SINK ON FRONT LEFT	<15 ppb	BS
L6776663-5	ENGLISH OFFICE FAUCET	* 5.400	REPLACED FAUCET/BS
L6776663-1	CONCESSION STAND SPIGOT	<15 ppb	BS
L6776663-4	CONCESSION STAND UTILITY SINK	ND	BS